

공공하수처리 시설명	시설용량 (m³/일)	유입수질							방류수질						
		BOD (mg/L)	TOC (mg/L)	SS (mg/L)	T-N (mg/L)	T-P (mg/L)	총대장균군 (개/mL)	pH	BOD (mg/L)	TOC (mg/L)	SS (mg/L)	T-N (mg/L)	T-P (mg/L)	총대장균군 (개/mL)	pH
장수	2,800	102.8	115.8	199.8	47.142	3.859	56,933	7.0	1.2	3.3	1.4	7.789	0.064	1.8	6.7
장계	3,200	105.5	149.1	206.3	45.201	4.250	58,367	7.2	1.7	5.5	1.7	5.851	0.139	1.5	6.7
산서	800	96.3	94.1	181.5	47.047	3.919	48,933	7.2	1.1	3.1	1.6	7.397	0.109	1.8	6.8
번암	500	92.9	98.6	175.9	46.864	3.960	47,300	7.2	1.3	3.2	1.5	6.861	0.101	1.6	6.8
천천	500	99.7	123.0	184.6	44.451	3.699	47,067	7.0	1.1	3.4	1.5	5.319	0.074	0.9	6.6
어전	120	107.8	122.8	171.3	51.248	4.658	52,500	7.1	2.8	4.5	2.2	10.178	0.206	12.3	6.7
오연	90	90.5	74.2	164.2	46.662	3.882	48,600	7.1	1.5	3.4	2.1	7.912	0.417	10.0	6.7
구암	85	99.9	130.5	175.6	52.536	4.032	51,400	7.3	1.6	6.1	2.4	8.299	0.396	6.6	6.9
오산	80	93.2	54.1	157.5	44.873	4.079	43,750	7.2	1.7	5.9	2.2	9.005	0.401	2.8	6.9
하평	80	98.7	109.9	153.8	47.288	3.878	50,000	7.2	2.7	4.6	1.8	9.648	0.256	3.3	6.7
수분·송계	70	102.3	64.0	156.3	46.343	4.197	48,000	7.1	1.5	2.6	1.5	8.940	0.262	3.3	6.7
양악	70	102.7	100.0	160.0	46.883	4.637	45,500	7.1	1.9	3.9	1.6	8.942	0.334	6.3	6.7
주촌	70	90.6	92.3	165.0	49.032	4.234	46,200	7.0	1.8	4.0	1.9	8.580	0.387	7.2	6.7
농소	60	103.0	168.2	158.0	50.670	4.369	54,200	7.1	2.7	6.4	2.2	7.937	0.309	9.0	6.7
금천	40	97.0	75.5	110.0	51.300	4.080	46,000	7.0	2.7	5.6	1.7	8.382	0.488	3.0	6.7
문성	40	110.2	139.0	164.0	50.400	4.326	48,000	7.3	2.9	4.2	2.4	7.308	0.449	11.0	6.6
원명덕	40	93.2	133.5	180.0	49.650	5.166	55,000	7.1	2.4	8.0	3.2	7.884	0.416	17.0	6.7
외림	35	99.8	56.0	110.0	51.990	4.566	44,000	7.0	2.8	4.1	0.8	8.826	0.436	1.0	6.6
덕산	25	84.4	69.0	115.0	44.970	4.290	41,000	7.1	2.4	4.8	1.2	8.574	0.452	1.0	6.8