

공공하수처리 시설명	시설용량 (㎡/일)	유입수질							방류수질							비 고
		BOD (mg/L)	TOC (mg/L)	SS (mg/L)	T-N (mg/L)	T-P (mg/L)	총대장균군 (개/㎖)	pH	BOD (mg/L)	TOC (mg/L)	SS (mg/L)	T-N (mg/L)	T-P (mg/L)	총대장균군 (개/㎖)	pH	
장수	2,800	98.1	131.7	157.7	46.021	3.508	50,290	7.1	1.8	4.3	1.5	8.052	0.070	1.0	6.8	
장계	3,200	98.1	128.8	174.5	45.232	3.444	50,032	7.1	2.0	5.8	1.9	7.276	0.136	1.6	6.7	
산서	800	86.9	81.2	118.2	46.380	3.350	45,323	7.2	1.1	3.1	1.4	8.016	0.114	0.6	6.8	
변암	500	93.6	95.8	149.5	46.252	3.488	46,774	7.2	1.3	4.0	1.3	8.862	0.124	0.9	6.8	
천천	500	86.4	115.4	127.6	42.080	3.204	45,258	7.0	1.3	3.6	1.3	5.725	0.083	0.8	6.6	
어전	120	101.1	119.0	174.0	49.860	3.485	49,250	7.2	2.4	6.2	1.7	10.115	0.246	11.0	6.6	
오연	90	86.2	84.0	90.0	51.855	4.073	45,750	7.2	2.8	4.3	1.7	9.818	0.490	7.5	6.6	
구암	85	112.3	161.1	111.0	52.298	4.575	47,250	7.2	2.9	6.5	2.0	10.218	0.490	8.5	6.8	
오산	80	95.9	59.2	108.0	48.548	3.356	51,000	7.3	2.7	5.8	2.0	9.399	0.382	9.0	6.9	
하평	80	99.4	124.0	131.0	47.393	3.809	43,750	7.2	1.9	6.0	2.1	9.936	0.332	6.3	6.8	
수분·송계	70	105.4	109.6	151.0	45.413	3.896	46,500	7.1	1.8	4.7	1.9	9.650	0.382	8.8	6.7	
양악	70	99.5	156.0	133.0	41.565	3.818	44,250	7.1	2.7	4.8	1.8	9.182	0.640	5.3	6.8	
주촌	70	100.2	92.0	108.0	51.300	3.875	50,750	7.1	2.0	4.9	1.9	9.527	0.316	4.0	6.7	
농소	60	107.2	137.1	129.0	52.103	3.414	51,000	7.2	2.2	6.5	1.8	9.363	0.253	8.5	6.7	
금천	40	78.0	74.5	96.0	48.120	4.152	39,000	7.1	2.5	4.6	1.9	8.700	0.936	6.0	6.7	
문성	40	79.2	94.0	100.0	56.730	3.582	50,000	7.1	1.2	5.9	1.6	10.344	0.986	4.0	6.6	
원명덕	40	105.4	159.0	96.0	53.790	4.500	59,000	7.2	2.9	9.0	1.2	11.136	0.794	9.0	6.8	
외림	35	106.4	116.5	80.0	49.890	4.650	44,000	7.1	2.9	3.0	0.8	8.754	0.766	2.0	6.8	
덕산	25	78.4	151.0	132.0	34.890	3.438	45,000	7.2	2.7	12.8	2.4	11.700	0.870	5.0	6.6	