

공공하수처리 시설명	시설용량 (m³/일)	유입수질							방류수질						
		BOD (mg/L)	TOC (mg/L)	SS (mg/L)	T-N (mg/L)	T-P (mg/L)	총대장균군 (개/mL)	pH	BOD (mg/L)	TOC (mg/L)	SS (mg/L)	T-N (mg/L)	T-P (mg/L)	총대장균군 (개/mL)	pH
장수	2,800	93.4	44.2	87.9	37.854	2.864	55,677	7.0	1.1	2.5	1.2	6.216	0.065	9.5	6.8
장계	3,200	94.7	56.4	95.4	37.527	3.079	56,806	7.1	1.1	3.9	1.2	6.739	0.062	5.7	6.7
산서	800	78.2	30.6	83.0	36.229	2.829	32,677	7.2	0.9	3.1	1.1	7.883	0.112	3.0	6.8
번암	500	78.3	39.1	87.4	35.927	2.765	32,903	7.1	0.9	3.3	1.1	7.240	0.080	2.4	6.8
천천	500	81.1	43.4	82.3	36.190	2.924	37,290	7.0	0.9	2.9	1.1	7.637	0.078	3.7	6.7
어전	120	96.0	55.2	78.5	38.828	2.789	36,500	7.1	1.3	3.5	1.7	9.963	0.154	12.5	6.7
오연	90	81.9	41.1	85.2	35.028	2.748	36,800	7.2	1.5	3.8	1.6	9.050	0.793	9.2	6.6
구암	85	91.1	36.2	87.1	39.078	3.127	51,400	7.2	1.4	3.8	1.7	8.904	0.421	6.8	6.9
오산	80	77.7	34.3	77.9	35.070	3.123	29,000	7.1	1.6	4.7	1.7	7.872	0.458	13.8	6.8
하평	80	90.9	38.7	73.0	37.193	2.651	32,750	7.1	1.5	2.8	1.8	7.032	0.357	6.5	6.8
수분.송계	70	79.1	39.8	76.5	36.660	3.131	35,250	7.2	1.2	2.2	2.0	8.616	0.296	13.0	6.7
양악	70	87.3	69.2	77.5	37.305	2.741	33,500	7.2	1.6	4.4	1.5	9.756	0.442	8.8	6.8
주촌	70	73.8	32.7	77.7	35.535	2.841	34,250	7.1	0.9	3.8	1.5	8.025	0.480	6.0	6.7
농소	60	91.8	77.0	94.6	35.768	3.308	43,250	7.1	1.1	4.9	1.7	8.469	0.351	4.8	6.7
금천	40	110.0	25.0	92.0	34.260	3.594	31,000	7.0	2.0	3.6	1.5	8.100	0.910	13.0	6.6
문성	40	92.0	36.3	80.0	40.350	3.906	33,000	7.2	1.2	3.2	2.0	8.172	0.612	4.0	6.7
원명덕	40	69.8	30.0	96.0	38.130	3.558	33,000	7.0	1.8	3.1	2.3	9.000	0.706	8.0	6.6
외림	35	97.2	47.9	104.0	42.660	3.684	32,000	7.1	3.3	6.0	1.4	9.708	0.749	4.0	6.7
덕산	25	69.4	38.3	84.0	38.790	3.828	25,000	7.0	2.2	3.7	1.7	9.432	0.751	3.0	6.9