

공공하수처리시설명	시설용량 (m³/일)	유입수질							방류수질						
		BOD (mg/L)	TOC (mg/L)	SS (mg/L)	T-N (mg/L)	T-P (mg/L)	총대장 균군 (개/mL)	pH	BOD (mg/L)	TOC (mg/L)	SS (mg/L)	T-N (mg/L)	T-P (mg/L)	총대장 균군 (개/mL)	pH
장수	2,800	128.8	61.0	144.8	42.526	3.961	71,767	7.1	2.3	4.2	1.8	7.205	0.052	15.0	6.7
장계	3,200	130.5	69.8	146.5	41.293	4.160	58,367	7.2	2.6	5.3	2.1	6.996	0.114	8.5	6.7
산서	800	99.8	43.3	111.7	40.766	3.803	51,467	7.2	1.0	3.5	1.5	7.176	0.141	2.3	6.8
번암	500	101.5	49.8	119.1	39.775	3.567	45,733	6.9	1.0	3.5	1.4	6.525	0.031	2.1	6.7
천천	500	105.0	55.4	120.0	39.603	3.534	52,467	7.0	0.9	4.0	1.5	6.406	0.046	2.3	6.6
어전	120	126.6	56.8	146.0	45.765	3.963	44,000	7.2	2.5	4.9	2.7	9.639	0.159	12.8	6.8
오연	90	93.6	37.6	130.0	41.108	4.017	40,000	7.1	2.3	4.9	1.9	7.083	0.424	4.5	6.8
구암	85	92.8	41.9	128.0	40.883	3.965	43,500	7.1	1.6	4.0	2.1	7.119	0.382	11.5	6.9
오산	80	117.5	27.4	105.0	46.898	4.538	62,000	7.2	2.2	4.8	2.2	6.303	0.616	17.0	7.0
하평	80	114.4	33.9	117.0	43.943	3.995	42,750	7.2	2.8	5.1	1.8	8.202	0.376	14.0	6.8
수분.송계	70	118.8	37.7	119.0	44.490	4.457	54,500	7.2	3.2	3.6	2.7	8.043	0.428	15.0	6.7
양악	70	114.0	71.6	122.0	42.765	4.365	38,000	7.2	2.4	5.7	2.6	8.610	0.436	15.8	6.7
주촌	70	108.6	43.4	107.0	42.390	4.581	47,500	7.1	2.2	6.8	2.0	10.092	0.871	19.5	6.7
농소	60	99.2	68.3	136.0	44.955	4.880	52,750	7.2	2.1	8.5	2.2	8.703	0.853	15.8	6.8
금천	40	112.0	44.1	120.0	43.380	4.116	55,000	7.0	1.0	5.4	1.8	9.684	0.646	11.0	6.6
문성	40	88.2	37.9	104.0	38.370	5.598	39,000	7.1	2.3	8.2	3.6	7.332	0.605	7.0	6.7
원명덕	40	141.6	56.0	132.0	47.760	4.014	47,000	7.0	2.3	10.8	3.3	6.744	0.874	9.0	6.9
외림	35	151.2	71.3	92.0	42.420	4.572	24,000	7.0	3.1	9.5	1.3	8.952	0.720	1.0	6.6
덕산	25	126.9	29.3	144.0	42.540	1.806	48,000	7.3	3.3	7.6	2.0	8.244	0.643	11.0	6.9